

RESOLUTION NO. 564

A RESOLUTION AUTHORIZING STAFF TO AWARD A CONTRACT TO MAKE AN EMERGENCY REPLACEMENT OF THE SACAJAWEA WAY AND AND LAFAYETTE WAY WATER LINES; AND DECLARING AN EMERGENCY EXISTS ACCORDING TO ORS 279.015, SECTION (3).

WHEREAS, at the regularly scheduled City Council meeting held June 2, 1986, in the City Council Chambers, 30000 SW Town Center Loop East, commencing at 7:30 o'clock p.m. Pacific Daylight Savings Time, a memorandum from Larry R. Blanchard, Public Works Director and titled "Waterline Replacement - Sacajawea Way and Lafayette Way" was approved by the City Council; and

WHEREAS, the above mentioned memorandum did identify that an emergency existed in regards to the fragile state of the water pipelines at these locations; and

WHEREAS, staff is in the process of completing plans and specifications for this project and anticipates completion on or before June 16, 1986; and

WHEREAS, staff developed a process for handling emergency repairs by accepting unit contract prices proposed by local contractors in case of an emergency situation such as this, and

will be using these prices as a guideline for final approval of a proposal for completion of this project.

NOW, THEREFORE, IT IS HEREBY RESOLVED by the City of Wilsonville that:

1. An emergency exists in that immediate replacement of water lines on Sacajawea Way and Lafayette Way are required due to the fragile, unstable condition of the pipe which poses a safety and health situation to the public. Findings are listed below, identifying the pipe conditions and the reasons for replacement.
 - (a) The pipeline is a 2" galvanized steel pipe with bronze, brass and copper fittings located within five feet of major underground electrical lines and massive deterioration has occurred due to electrolysis.
 - (b) This pipe was scheduled for replacement in 1986-87. Due to the numerous repairs done over the past five years, this pipe section was scheduled for replacement. Two recent repairs in May of 1986 exposed the pipe, which revealed the need to replace the pipe as soon as possible.
 - (c) Normal bidding time frame is between thirty

and forty-five days. Due to the fragil condition of this pipe, immediate replacement is required.

2. According to ORS 279.015, Section 3, the City Council can waive the normal bidding process by declaring an emergency exists to provide immediate response.
3. Authorize staff to approve a contractor to complete the replacement of the water lines on Sacajawea Way and Lafayette Way. Final contract approval shall be authorized by the City Administrator.
4. The Finance Director, by his signature below, has verified that funds are available in the account numbers mentioned for payments of all billings listed in the budget for fiscal year 1986-87.


Total Project Account No.	7221100	\$43,000.00
Engineering		\$ 3,600.00
Construction		\$36,000.00
Miscellaneous Expense		\$ 3,400.00

Ray Horton 6-16-86
FINANCE DIRECTOR DATE

5. All payments for construction billings and services during construction shall be approved for payment by the Public Works Director, or duly authorized representative. All change orders shall be approved by City Council, prior to payment; all field changes shall be approved by the Public Works Director or duly authorized representative prior to payment of field changes.


6. The final payment shall not be paid until the City Council has authorized said payment to be made.

ADOPTED by the City Council of the City of Wilsonville at a regular meeting thereof this 16 day of June, 1986, and filed with the Wilsonville City Recorder this same date.



A. G. MEYER, Mayor

ATTEST:



VERA A. ROJAS, City Recorder